C E R T I F I K A T

TYPE APPROVAL CERTIFICATE 0275

WITH REGULATIONS ON PRODUCTION CONTROL

KEYWORD: DOMESTIC WATER
Fittings

BBR 6:62
BSAB PN

SANHA

NiroSan Multifit, Pressfittings system

Certificate holder

SANHA Kaimer GmbH & Co. Holding KG, im Teelbruch 80, DE– 45219 ESSEN.
Tel. +49 2054 925 / 0, Fax. +49 2054 925 / 260, Hompage: www.sanha.com

Information submitted by

SANHA Kaimer GmbH & Co Holding KG, Office Sweden, Träffgatan 2, SE-136 44 Handen.
Tel.+46 (0)8 777 76 40. Fax. +46 (0)8 777 76 90.

Product

Stainless steel pipe system and pressfittings in dimensions
Ø 15, 18, 22, 28, 35, 42, 54, 76,1, 88,9, 108 mm.

Application

Pipe system for use in domestic water installations with visible montage.
Maximum operating pressure 1,0 Mpa.

Approval

The product is approved with respect to the following paragraphs in the Swedish Building Regulations (BBR):

Construction products with confirmed characteristics	1:4
Tap water installation	6:62
-Growth of microorganisms	6:622
-Design	6:625

Within the prescribed field of application the product meets the criteria stipulated in PBL, Cap. 8, 4§ Regulations governing the technical properties of materials used in construction works:
3. Protection in terms of hygiene, health and environment

Period of Validity

Type approval issued 31/1/2012. Registration no.074/12. Type approval valid until 31/1/2017.
The type approval is granted on condition that the holder of the certificate reports Annually to Swedcert on quality control carried out.
This type approval certificate replaces the certificate of the same number, issued 7/11/2006. Reg. no. 249/06.
On delivery to site of installation the product must be accompanied by a certificate of assurance from the manufacturer, in accordance with BFS 2011:19, TYP 5.

SWEDCERT AB

Appendix 1	Associated documents	31/1/2012
Appendix 2	Product markings	31/1/2012
Appendix 3	Directions for quality control	31/1/2012
Appendix 4	Basis of approval	31/1/2012

Bertil Wolgast
MD

Rozalia Gyarmati
TM